

**Wood Engineering, Inc.**

Edward N. Wood, P.E.  
Civil – Mechanical – Structural  
311 Smethwick Drive  
Umpqua, OR 97486  
541-459-2994

Certification Blast Valve Test  
October 29, 2008

In Accordance with TM 5-1300/NAVFAC P-397/AFR 88-22  
Section 6.1.2

The ASR 101-BV, 7-bar blast valve was subjected to a pneumatic pressure test of 120 pounds per square inch - gauge (8.2 bar) for a sustained period of time of two hours.

At the conclusion of the test the valve was inspected for functionality and defects.

The valve continued to operate as designed with no defects observed or found.

  
Edward N. Wood, P.E.



6-36-16-

