




10600 DRMSBY PARK PL STE 600
LOUISVILLE KY 40223-6158
P O BOX 35890
LOUISVILLE KY 40232-5890
502.637.0631
www.aafintl.com

CERTIFICATE OF CONFORMANCE

**American Safe Room
Roseburg, OR**

**AAF HEPA Filter
Part No. 905-000-739
Style Code: 13N74J1T2A5**

AAF Certifies above filters when tested in accordance with MIL-STD-282, will meet the minimum requirement of 99.97% DOP Efficiency. This is based on the American Safe Room design of the Filter Housing and more modern AAF filter test techniques which have been proven by comparison testing at US Dept. of Energy's Filter Test Facility at Oak Ridge, Tennessee.



**Ben Franklin, Director
Nuclear Environmental Systems
28 JAN 2003**

